



## STATE PUBLIC HEALTH LABORATORY, PUNE

Dy Director tele No. 26330509 (P)  
Office Tele No. 26330225 (O)

Cantonment water works campus, Near Saint Mary Church, Staveley  
road, Pulgate, Pune-411 001 (MH) INDIA  
Email ID : sphlmis@gmail.com , statehealthlab@gmail.com  
website : arogya.maharashtra.gov.in

HEALTH  
SERVICES:

No. SPHLPUNE / sk-80/Bact. Section/water analysis report/ 1068 / 2025  
Date : 21/07/2025

### Bacteriological Report of water Sample

Sender's Name Orchids The International School, Survey No. 50, Wadgaon Sheri, Pune.  
Sender's letter No. & date --/ 16-07-2025  
Lab. Reference No. 116 / 689-690  
Date of sample collection 16/07/2025  
Date of sample received 16/07/2025  
Analysis start date 16/07/2025

#### Sample Description

#### Bacteriological Analysis result

#### Most Probable Number of bacteria found per 100 ml of Water Sample

Coliforms	Thermotolerant Coliforms	E.coli	Conclusion
-----------	-----------------------------	--------	------------

1.	Orchids The International School, Wadgaon Sheri - Raw Water (Tap)	0	-	-	Potable
2.	Orchids The International School, Wadgaon Sheri - RO Water	0	-	-	Potable

**Remark:** If water sample found non-potable, it can be used for drinking purposes after proper treatment and ascertaining its bacteriological quality for potability by retesting.

**Note:** Above sample/samples is/are not collected by this laboratory and result is/are as per submitted sample/samples.

Fee Rs. 680/-

Receipt No. : 7760717

Date : 16/07/2025

Chief Bacteriologist

State Public Health Laboratory, Pune

Principal

ORCHIDS THE INTERNATIONAL SCHOOL  
WADGAON SHERI, PUNE

School Manager

Orchids The International School  
Wadgaon Sheri, Pune- 411014.